

SAFE DRINKING WATER CERTIFICATE

No. 25

Date: 8.5.23

It is certified that an inspection team headed by P.H.E.D Section Rairakhol(Name of Officer with designation) from Sanjeev K. Patra (Asst. Ex. Engineer)(Name of Department/Office) inspected the P.H.E.D Section office Rairakhol(Name & Address of the School) on 06-05-2023 (date of school) and found that thePrabhujee English medium school, Rajbati, Rairakhol (Name of School) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

Attach the
Spectro Analytical
Lab Report
SBL.

Signature with Seal [Signature]

Assistant Executive Engineer

Name P.H. Section, Rairakhol

Sambalpur

Designation [Signature]Name & Address of the Office/Department: Sanjeev K. Patra

Asst. Ex. Engineer

P.H. E.D Section office

Rairakhol

To

Prabhujee English medium school
Rajbati, Rairakhol, Dist-Sambalpur

(Name & Address of the Institution)

[Signature]

Secretary

Kriya Yoga Foundation Trust

Kriya Yoga Ashram

VSS Naagar, Bhubaneswar-7

[Signature]


Principal


Prabhujee English Medium School
Rajbati, Rairakhol, Sambalpur


Customer Name : PHEO
Sampling Location : Prabhujee English Medium School, Rairakhol
Sample / Source : Supply water
Sample collection Date : 06.05.2023
Sample Receipt Date : 06.05.2023
Analysis completed on : 06.05.2023

Sr. No.	PARAMETERS	TEST METHODS	OBTAINED RESULTS	LIMITS (Max.)	
				Acceptable Limit	Permissible Limit
1	Colour, Hazen Units	IS :3025 (Part-4) :1983, RA-2014	6.058	5 HU	15 HU
2	Odour	IS:3025 (Pt-5):1983, RA-2012	Agreeable	Agreeable	Agreeable
3	Free Residual Chlorine	IS: 3025 (P-26): 1986, RA-2009	0	0.2 mg/L	1 mg/L
4	Ammonia as N	IS: 3025 (P-34), RA-2009	0.051	0.5 mg/L	No relaxation
5	pH	IS: 3025 (Pt-11): 1983, RA-2006	8.11	6.5 - 8.5	No relaxation
6	Taste	IS :3025 (P-7 & 8) 1984, RA-2012	Agreeable	Agreeable	Agreeable
7	Turbidity	IS: 3025 (Pt-10): 1984, RA-2012	1.58	1 NTU	5 NTU
8	Conductivity	IS: 3025 (Pt-14):1984, RA-2002	311.8	NA	NA
9	Total Dissolved Solids	IS: 3025 (Pt-16): 1984, RA - 2006	188	500 mg/L	2000 mg/L
10	Total Suspended Solids	IS: 3025 (Pt-17) 1984, RA-2012	0	10 mg/L	50 mg/L


End of Report


Signature (Analyst)

SPECTRO Analytical Lab

Signature (Lab In-Charge)



Secretary
Kriya Yoga Foundation Trust
Kriya Yoga Ashram
VSS Nagar, Bhubaneswar-7


Principal
Prabhujee English Medium School
Rajbati, Rairakhol, Sambalpur

OFFICE OF THE NOTIFIED AREA COUNCIL, REDHAKHOL
(ODISHA), DIST- SAMBALPUR



E-mail:- eonacrdl@gmail.com
Ph. No/ Fax No. 06644- 253466



Letter No 784

Date 09/05/2023


To


Prabhujee English Medium School
Rajabati
Rairakhhol
Sambalpur-768106


SAFE SANITARY CONDITION CERTIFICATE


It is certified that an inspection team headed by Jyoti Ranjan Behera (Junior sanitation Expert) From N.A.C Redhakhol inspected the Prabhujee English Medium School, Rajbati, Rairakhhol, Sambalpur-768106 on Dated 09/05/2023 and found that Prabhujee English Medium School, Rajabati, Rairakhhol has safe sanitary facility for the students and members of staff of the institution and is maintaining the hygienic condition in school building and the campus as per norms prescribed by the Central/State/U.T/Govt.

Date Of inspection: 09-05-2023


Executive Officer
Executive Officer
N.A.C Redhakhol
Redhakhol


Sanitation Expert
N.A.C Redhakhol


Secretary
Kriya Yoga Foundation Trust
Kriya Yoga Ashram
VSS Naagar, Bhubaneswar-7


Principal
Prabhujee English Medium School
Rajabati, Rairakhhol, Sambalpur